

Doral Arrowwood – Database Notes

Table 1 Database Notes

<p>Data Collection</p>	<p><u>Data Logger:</u> <u>Data Collection Interval:</u> <u>Collection Method:</u></p>	<p>Obvius Aquisuite (AMDG) Datalogger samples all sensors approximately once per second and record five-minute totals (of pulse or digital sensors) or averages (of analog sensors) Obvius Upload to CDH energy server and to the Obvius Building Manager Online (BMO) system</p>
<p>Site Information</p>	<p><u>Cogeneration Units:</u> <u>Nameplate Capacity:</u> <u>Heat Recovery Medium:</u> <u>Heat Recovery Uses:</u> <u>Excess Heat:</u></p>	<p>3 Tecogen InVerde 100 300 kW Hot glycol/water loop Space Heating, Domestic Hot Water Rejected from hot glycol/water loop to heat exchanger with dump radiator</p>
<p>DG/CHP Generator Electrical Output</p>	<p><u>Engineering Units:</u> <u>Energy Measurement (net/gross):</u> <u>Measurement Type:</u> <u>Generator Power Measurements:</u> <u>Parasitic Power Measurements:</u></p>	<p>kWh Net calculated: gross - parasitic Accumulated energy per interval 3 total – one for each engine One for entire parasitic panel</p>
<p>DG/CHP Generator Electrical Output Demand</p>	<p><u>Engineering Units:</u> <u>Measurement Type:</u></p>	<p>kW From power measurement, based on peak 5-min power</p>
<p>DG/CHP Generator Fuel Input</p>	<p><u>Engineering Units:</u> <u>Measurement type:</u></p>	<p>CF Engine heat rate calculated from utility data and measured generator</p>
<p>DG/CHP Useful Heat Recovery</p>	<p><u>Engineering Units:</u> <u>Heat Measurement Type:</u></p>	<p>MBtu Contrec 212 BTU Meter measures flow and temperatures across useful loads</p>

Doral Arrowwood – Database Notes

DG/CHP Unused Heat Recovery	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	MBtu (calculated value) Common flowmeter, additional temperature measurements across dump HX
DG/CHP Status/Runtime	<u>Engineering Units:</u> <u>Measurement Type:</u>	0 – 1, System On/System Off
Facility Purchased Energy	<u>Engineering Units:</u> <u>Measurement Type:</u>	kWh Metered by datalogger
Facility Purchased Demand	<u>Engineering Units:</u> <u>Measurement Type:</u>	kW Metered by datalogger
Other Facility Gas Use	<u>Engineering Units:</u> <u>Measurement Type:</u>	Not Collected

Doral Arrowwood – Database Notes

Table 2 Event Timeline

Date	Event
December 5, 2012	Logging begins
May 13, 2013	Datalogger stops communications, TLS2 installed
July 31, 2013	Reestablish datalogger communications. Data collection resumes

Doral Arrowwood – Database Notes

Range Checks

Table 3. Range Checks

Data Point	Units	Hourly Data Calculation Method	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output (WG_d)	kWh/int	Sum	-5	30	
DG/CHP Generator Output Demand (WG_KW_d)	kW	Max	-20	360	
DG/CHP Generator Gas Use (FG_d)	cf/int	Sum	0	350	Utility Gas Pulse
Total Facility Purchased Energy (WT_d)	kWh/int	-	0	100	
Total Facility Purchased Demand (WT_KW_d)	kW	-	1	1200	
Other Facility Gas Use (FT_d)	cf/int	-	-	-	Not collected
Useful Heat Recovery (QHR_d)	MBtu/int	-	0	300	Calculated Value
Unused Heat Recovery (QD_d)	MBtu/int	-	0	300	Calculated Value
Status/Runtime of DG/CHP Generator (SG_d)	hr	-	0	1	0 – 1, System On/System Off
Ambient Temperature (TAO)	°F	Avg	-30	130	WUG Airport Code - JFK

Notes:

1. This table contains values from *doral.csv*

Doral Arrowwood – Database Notes

Relational Checks

Table 4. Relational Checks

Evaluated Point	Criteria	Result

Notes:

1. This table contains values from *relational_checks.pro*

