

# North Rockland High School – Database Notes

Table 1 Database Notes

<b>Data Collection</b>	<u>Data Logger:</u> <u>Data Collection Interval:</u> <u>Collection Method:</u>	Obvius AcquiSuite A8812 15 – Minute Obvius Upload Manager to Frontier Energy Servers
<b>Site Information</b>	<u>Cogeneration Units:</u> <u>Nameplate Capacity:</u> <u>Heat Recovery Medium:</u> <u>Heat Recovery Uses:</u>	One (1) Aegenco PS - 75 75 kW Hot Water Domestic Hot Water (DHW) and space heating
<b>DG/CHP Generator Electrical Output</b>	<u>Engineering Units:</u> <u>Energy Measurement (net/gross):</u> <u>Measurement Type:</u>	kWh Net Power (calculated from gross measurement and stipulated parasitic) Measured using 15 min average kWh.
<b>DG/CHP Generator Electrical Output Demand</b>	<u>Engineering Units:</u> <u>Energy Measurement (net/gross):</u> <u>Measurement Type:</u>	kW Net Power (Provided by data file) Measured using 15 min average kW.
<b>DG/CHP Generator Fuel Input</b>	<u>Engineering Units:</u> <u>Measurement type:</u>	CFh Provided Cubic feet per interval.
<b>DG/CHP Useful Heat Recovery</b>	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	MBtu/hr Calculated from 15 minute analog flow and temperature data from an Badger 380 - Btu Meter
<b>DG/CHP Unused Heat Recovery</b>	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	- -
<b>Facility Purchased Energy</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	- -

## North Rockland High School – Database Notes

<b>Facility Purchased Demand</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	- -
<b>Other Facility Gas Use</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	- -

**Table 2 Event Timeline**

<b>Date</b>	<b>Event</b>
October 1, 2020	Data collection begins
October 12, 2020	Added to NYSERDA website.

# North Rockland High School – Database Notes

## *Range Checks*

**Table 3. Range Checks**

<b>Data Point</b>	<b>Units</b>	<b>Hourly Data Calculation Method</b>	<b>Database Lower Range</b>	<b>Database Upper Range</b>	<b>Notes</b>
DG/CHP Generator Output (WG)	kWh/int	Sum	-10	21.25	-
DG/CHP Generator Output Demand (WG_KW)	kW	Max	-10	85	-
DG/CHP Generator Gas Use (FG)	cf/int	Sum	0	2000	-
Useful Heat Recovery (QU)	MBtu/hr	Avg	0	1000	-
Unused Heat Recovery (QD)	MBtu/hr	Avg	0	1000	-
Ambient Temperature (TAO)	°F	Avg	-20	130	<i>WUG Airport Code - SWF</i>

# North Rockland High School – Database Notes

## *Relational Checks*

**Table 4. Relational Checks**

<b>Evaluated Point(s)</b>	<b>Criteria</b>	<b>Result</b>
Electricity Generated	Fuel Consumed > 0 and Electricity Generated Invalid	Fuel Consumed = invalid
Fuel Consumed	Electricity Generated > 0 and Fuel Consumed Invalid	Electricity Generated = invalid