

Walmart #6356 – Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	SolarCity Daily sftp 15 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	180° 10° 240.24 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Accumulator
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Calculated

Table 2 Event Timeline

Date	Event
December 1, 2013	Monitored data collected and posted on the NYSERDA DG Website

Table 3 Range Checks

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	150	
DG/CHP Generator Output Demand	Max	kW	0	600	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code - POU

Notes: Table contains values from *walmart6356.csv*