

Palace Hotel – Database Notes

Table 1 Database Notes

Data Collection	<u>Data Logger:</u> <u>Data Collection Interval:</u> <u>Collection Method:</u>	Obvius Aquisuite 15– minute Obvius Upload
Site Information	<u>Cogeneration Units:</u> <u>Nameplate Capacity:</u> <u>Heat Recovery Medium:</u> <u>Heat Recovery Uses:</u> <u>Excess Heat:</u>	(12) – 65 kW Capstone Microturbines 780 kW Hot Water Domestic Hot Water, Space Heating/Cooling Rejected from chiller heat exchanger dump radiator (heating season) or DHW loop heat exchanger dump radiator (cooling season)
DG/CHP Generator Electrical Output	<u>Engineering Units:</u> <u>Energy Measurement (net/gross):</u> <u>Measurement Type:</u> <u>Generator Power Measurements:</u> <u>Parasitic Power Measurements:</u>	KW/kWh Net calculated: gross minus parasitic load from chiller Accumulated energy per interval 2 – one for each bank of (6) microturbines One time measurement
DG/CHP Generator Electrical Output Demand	<u>Engineering Units:</u> <u>Measurement Type:</u>	kW From energy measurement, based on peak 15-min power
DG/CHP Generator Fuel Input	<u>Engineering Units:</u> <u>Measurement type:</u>	CF 4 – 20 mA Hot wire anemometer
DG/CHP Useful Heat Recovery	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	MBtu (calculated value) BTU meter installed on hot water header leaving microturbines. Meter reports, flow, temperatures, and BTUs. Chilled water produced by absorption chiller is also measured, but not reported in useful heat recovery, as it is derived from the hot water produced by the turbines.

Palace Hotel – Database Notes

DG/CHP Unused Heat Recovery	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	Not collected
DG/CHP Status/Runtime	<u>Engineering Units:</u> <u>Measurement Type:</u>	0 – 1, System On/System Off
Facility Purchased Energy	<u>Engineering Units:</u> <u>Measurement Type:</u>	Not collected
Facility Purchased Demand	<u>Engineering Units:</u> <u>Measurement Type:</u>	Not collected
Other Facility Gas Use	<u>Engineering Units:</u> <u>Measurement Type:</u>	Not collected

Table 2 Event Timeline

Date	Event
November 1, 2013	Logging begins.
November 4, 2021	RSP Systems replaced the power meter for each turbine bank at the site.
November 29, 2021	Back data from replacement power meters uploaded to DER Website.

Palace Hotel – Database Notes

Range Checks

Table 3. Range Checks

Data Point	Units	Hourly Data Calculation Method	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output (WG_d)	kWh/int	Sum	0	40	
DG/CHP Generator Output Demand (WG_KW_d)	kW	Max	0	300	
DG/CHP Generator Gas Use (FG_d)	cf/int	Sum	0	12000	
Total Facility Purchased Energy (WT_d)	kWh/int	-	9	100	
Total Facility Purchased Demand (WT_KW_d)	kW	-	9	400	
Other Facility Gas Use (FT_d)	cf/int	-	0	90000	
Useful Heat Recovery (QHR_d)	MBtu/int	-	-500	6000	
Unused Heat Recovery (QD_d)	MBtu/int	-	-	-	Not installed
Status/Runtime of DG/CHP Generator (SG_d)	hr	-	0	1	0 – 1, System On/System Off
Ambient Temperature (TAO)	°F	Avg	-20	130	WUG Airport Code - LGA

Notes:

Palace Hotel – Database Notes

1. This table contains values from *palace_hotel.csv*

Relational Checks

Table 4. Relational Checks

Evaluated Point	Criteria	Result

Notes:

1. This table contains values from *relational_checks.pro*

