

## Verizon – Clinton Ave – Database Notes

Table 1 Database Notes

<b>Data Collection</b>	<u>Data Logger:</u> <u>Data Collection Interval:</u> <u>Collection Method:</u>	Obvius AcquiSuite (Site) 1 Min Obvius Upload Manager to CDH Servers
<b>Site Information</b>	<u>Cogeneration Units:</u> <u>Nameplate Capacity:</u> <u>Heat Recovery Medium:</u> <u>Heat Recovery Uses:</u> <u>Excess Heat:</u>	ClearEdge Power PureCell® Model 400 Fuel Cell 400 kW None
<b>DG/CHP Generator Electrical Output</b>	<u>Engineering Units:</u> <u>Energy Measurement (net/gross):</u> <u>Measurement Type:</u>	kWh Gross Accumulated kWh
<b>DG/CHP Generator Electrical Output Demand</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	kW Instantaneous kW Output
<b>DG/CHP Generator Fuel Input</b>	<u>Engineering Units:</u> <u>Measurement type:</u>	cf Instantaneous Fuel Input, converted from kg/h to cf/interval (lhv, 48,667 kJ/kg). Fuel Cell internal meter.
<b>DG/CHP Useful Heat Recovery</b>	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	
<b>DG/CHP Unused Heat Recovery</b>	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	
<b>DG/CHP Status/Runtime</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	

## Verizon – Clinton Ave – Database Notes

<b>Facility Purchased Energy</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	
<b>Facility Purchased Demand</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	
<b>Other Facility Gas Use</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	

**Table 2 Event Timeline**

<b>Date</b>	<b>Event</b>
5/8/2014	Data uploaded to NYSERDA website. Begin daily upload.

## Verizon – Clinton Ave – Database Notes

### Range Checks

Table 3. Range Checks

Data Point	Units	Hourly Data Calculation Method	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output (WG_d)	kWh/int	Sum	0	10	
DG/CHP Generator Output Demand (WG_KW_d)	kW	Max	0	500	
DG/CHP Generator Gas Use (FG_d)	cf/int	Sum	0	100	<i>kg/h → cf/int (lhv, 48,667 kJ/kg)</i>
Total Facility Purchased Energy (WT_d)	kWh/int	-			
Total Facility Purchased Demand (WT_KW_d)	kW	-			
Other Facility Gas Use (FT_d)	cf/int	-			
Useful Heat Recovery (QHR_d)	MBtu/int	-			
Unused Heat Recovery (QD_d)	MBtu/int	-			
Status/Runtime of DG/CHP Generator (SG_d)	hr	-			
Ambient Temperature (TAO)	°F	Avg	-20	130	

Notes:

1. This table contains values from *vznyc\_clinton.csv*

# Verizon – Clinton Ave – Database Notes

## *Relational Checks*

Table 4. Relational Checks

Evaluated Point	Criteria	Result

Notes:

1. This table contains values from *relational\_checks.pro*