

## LEFRAK - WEST SIDE MANOR – DATABASE NOTES

**Table 1 Database Notes**

<b>Data Collection</b>	Data Logger: Data Collection Interval: Collection Method:	Tecogen Installed CHPInsight 15 – Minute Nightly FTP upload to Frontier Energy (FE) servers
<b>Project Information</b>	DER Unit (make & model): Nameplate Capacity: Heat Recovery Medium: Heat Recovery Uses: Excess Heat:	One (1) Tecogen Tedom Micro T35 35 kW Hot Water Domestic Hot Water (DHW) No heat rejection
<b>DER Electricity Generated (WG)</b>	Engineering Units: Energy Measurement (net/gross): Measurement Type:	kWh/hour Net Power Net power calculated using kW measurements from Tecogen Tedom Micro T35 Unit and stipulated parasitic loads
<b>DER Fuel Consumed (FG)</b>	Engineering Units: Measurement type:	cfh Calculated using accumulated cf from gas meter
<b>DER Heat Used (QU)</b>	Engineering Units: Heat Measurement Type:	MBtu/hour Calculated from accumulated BTU values from installed Onicon System-10 meter

## LEFRAK - WEST SIDE MANOR – DATABASE NOTES

**Table 2 Event Timeline**

<b>Date</b>	<b>Event</b>
November 10, 2020	Data collection begins.
January 25, 2021	Added to NYSERDA website.
January 26, 2021	0.88 correction factor applied to heat recovery (QU) to bring the measured full load heat recovery into alignment with the rated full heat output.

## LEFRAK - WEST SIDE MANOR – DATABASE NOTES

### *Range Checks*

Table 3 Range Checks

<b>Data Point</b>	<b>Units</b>	<b>Database Lower Range</b>	<b>Database Upper Range</b>	<b>Notes</b>
<b>DER Electricity Generated</b>	kWh/hour	0	40	
<b>DER Fuel Consumed</b>	cfh	0	500	
<b>DER Heat Used</b>	MBtu/hour	0	250	
<b>Ambient Temperature</b>	°F	-20	130	NOAA Airport Code - KLGA

## LEFRAK - WEST SIDE MANOR – DATABASE NOTES

### ***Relational Checks***



**Table 4 Relational Checks**

<b>Evaluated Point(s)</b>	<b>Criteria</b>	<b>Result</b>
Electricity Generated Fuel Consumed	Daily Electric Efficiency < 0% HHV and > 100% HHV	Electricity Generated = invalid Fuel Consumed = invalid Heat Used = invalid Heat Rejected = invalid

APPENDIX A – HEAT RECOVERY ADJUSTMENT CALCULATIONS

# APPENDIX A – HEAT RECOVERY ADJUSTMENT CALCULATIONS

Reported heat recovery regularly exceeds manufacturers ratings by 10%, resulting in a high calculated system efficiency. Frontier Energy developed and employed a correction factor of 0.88 to bring the measured full load heat recovery into alignment with the rated full heat output.



# APPENDIX A – HEAT RECOVERY ADJUSTMENT CALCULATIONS

Fundamental flow and temperature data was reviewed to identify the cause of the high heat recovery measurements. Measured flow is under the design flow (13.16 gpm) and measured supply temperature is in alignment with the HX-1 supply temperature (194 °F) called out on the mechanical drawings. The measured return temperature from HX-1 is considerably lower than the design temperature (150 °F) on the drawings. The HX-1 return temperature sensor should be inspected to ensure it is fully inserted into thermowell and that thermal paste has been applied.

