

LADS Avenue Associates, LLC – Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Locus Daily Email 5 min
Site Information	Solar Panels: Azimuth: Tilt: Nameplate Capacity:	1 150° 20° from horizontal 341.33 kW DC
DG/CHP Solar Panel Output	Engineering Units: Measurement Type: Power Measurements:	kWh Interval
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Interval Max

Table 2 Event Timeline

Date	Event
June 9, 2014	Monitored data collected and posted on the NYSERDA DG Website

LADS Avenue Associates, LLC – Database Notes

Range Checks

Table 3. Range Checks

Data Point	Hourly Data Method	Units	Sensor Lower Range	Sensor Upper Range	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	-	0	35	<i>Interval Size: 5 mins</i>
DG/CHP Generator Output Demand	Max	kW	0	-	0	400	
Ambient Temperature	Avg	°F	-20	130	-20	130	WUG Airport Code - JFK

Notes:

1. Table contains values from *lads_avenue.csv*