

Diamond-Broadway-0051 – Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Obvius 5min Direct Upload 5 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	188° 5° 129.285 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Accumulator
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Calculated

Table 2 Event Timeline

Date	Event
July 21, 2015	Monitored data collection began
August 11, 2015	Monitored data posted on the NYSERDA DG Website

Table 3 Range Checks

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	50	
DG/CHP Generator Output Demand	Max	kW	0	200	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code - LGA

Notes: Table contains values from *broadway_50.csv*