

The Strand – Database Notes

Table 1 Database Notes

Data Collection	<u>Data Logger:</u> <u>Data Collection Interval:</u> <u>Collection Method:</u>	Obvius AcquiSuite A8812 & Expansion Board A8332 1 – Minute Nightly Obvius Building Manager Online upload to CDH servers.
Site Information	<u>Cogeneration Units:</u> <u>Nameplate Capacity:</u> <u>Heat Recovery Medium:</u> <u>Heat Recovery Uses:</u> <u>Excess Heat:</u>	Tecogen InVerde 100 100 kW Hot Water DHW, pool, and space heating Rejected to atmosphere using dump radiator
DG/CHP Generator Electrical Output	<u>Engineering Units:</u> <u>Energy Measurement (net/gross):</u> <u>Measurement Type:</u>	kWh Gross power measurement from InVerde engine controller Accumulated kWh
DG/CHP Generator Electrical Output Demand	<u>Engineering Units:</u> <u>Measurement Type:</u>	kW Calculated : accumulated kWh / int * # intervals
DG/CHP Generator Fuel Input	<u>Engineering Units:</u> <u>Measurement type:</u>	CF Pulse output from Romet RM2000 utility gas meter
Other Fuel Input	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	- -
Utility Energy Import	<u>Engineering Units:</u> <u>Measurement Type:</u>	kWh Calculated using kW value from InVerde modbus reading
Utility Energy Import Demand	<u>Engineering Units:</u> <u>Measurement Type:</u>	kW Modbus signal from InVerde.

The Strand – Database Notes

DG/CHP Useful Heat Recovery	<u>Engineering Units:</u> <u>Measurement Type:</u>	<u>MBtu/hr</u> Calculated using 1-minute flow and temperature measurements
DG/CHP Rejected Heat Recovery	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	MBtu/hr Calculated using 1-minute flow and temperature data.
Generator Status	<u>Engineering Units:</u> <u>Measurement Type:</u>	Hours 0 to 1, system on / system off. Generator output must be above 25 kW to be considered on.
Ambient Temperature	<u>Engineering Units:</u> <u>Measurement Type:</u>	Deg. F Weather Underground airport code NYC.

Table 2 Event Timeline

Date	Event
August 18, 2015	Data collection begins
January 11, 2021	Gas data stops.
October 21, 2022	Gas data stipulated, from 1/11/21 to present, using measured power and gas prior to gas meter failure. See Appendix – Gas Calc for details.

The Strand – Database Notes

Range Checks

Table 3. Range Checks

Data Point	Units	Hourly Data Calculation Method	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output (WG_d)	kWh/int	Sum	0	2	
DG/CHP Generator Output Demand (WG_KW_d)	kW	Max	0	100	$WG_KW_d = WG_d * \# \text{ Intervals}$
DG/CHP Generator Gas Use (FG_d)	Cfh/int	Sum	0	20	
Total Facility Purchased Energy (WT_d)	kWh/int	-	0	10	
Total Facility Purchased Demand (WT_KW_d)	kW	-	0	600	
Other Facility Gas Use (FT_d)	cf/int	-	-	-	
Useful Heat Recovery (QHR_d)	MBtu/int	-	0	800	
Unused Heat Recovery (QD_d)	MBtu/int	-	0	800	
Status/Runtime of DG/CHP Generator (SG_d)	hr	-	0	1	0-1, System On/System Off
Ambient Temperature (TAO)	°F	Avg	-20	130	WUG Airport Code: NYC

Notes:

1. This table contains values from *strand.csv*

The Strand – Database Notes

Relational Checks

Table 4. Relational Checks


Evaluated Point	Criteria	Result

Notes:

1. This table contains values from *relational_checks.pro*

THE STRAND – APPENDIX A

Gas data is calculated from power generation by using gas curve developed from the measured power and gas data, prior to the gas meter failure on 1/11/21, for the Tecogen InVerde Ultra INV-100 unit.



Power generation (WG_KW), gas consumption (FG):

$$FG = -0.00223(WG_KW)^2 + 12.22245(WG_KW) + 6.3690958$$