

Table 1. Database Notes

<b>Data Collection</b>	Data Logger: Data Collection Interval: Collection Method:	Obvius AcquiSuite A8812 15 - Minute Nightly Obvius Building Manager Online upload to CDH servers.
<b>Site Information</b>	Cogeneration Units: Nameplate Capacity: Heat Recovery Medium: Heat Recovery Uses: Excess Heat:	Dresser Rand SFGLD 360 Reciprocating Engine w/ Synchronous Generator 450 kW Hot Water Digester and food waste tank heating Rejected to atmosphere using dump radiator
<b>DG/CHP Generator Electrical Output</b>	Engineering Units: Energy Measurement (net/gross): Measurement Type:	kWh Gross Generator Power Pulse output from Shark 100 revenue grade power meter
<b>DG/CHP Generator Electrical Output Demand</b>	Engineering Units: Measurement Type:	kW Calculated from generator electrical output; max kW / int * # intervals
<b>DG/CHP Generator Fuel Input</b>	Engineering Units: Measurement type:	CF 4-20 mA output from Sage SIP gas meter
<b>Other Fuel Input</b>	Engineering Units: Heat Measurement Type:	- -

<b>Utility Energy Import</b>	Engineering Units: Measurement Type:	- -
<b>Utility Energy Import Demand</b>	Engineering Units: Measurement Type:	- -
<b>DG/CHP Useful Heat Recovery</b>	Engineering Units: Measurement Type:	- -
<b>DG/CHP Rejected Heat Recovery</b>	Engineering Units: Heat Measurement Type:	- -
<b>Generator Status</b>	Engineering Units: Measurement Type:	Hours 0 to 1, system on / system off. Generator output must be above 50 kW to be considered on.
<b>Ambient Temperature</b>	Engineering Units: Measurement Type:	Deg. F Weather Underground airport code MSS.

Table 2 Event Timeline

<b>Date</b>	<b>Event</b>
5/31/2021	New gas meter installed; devise resumes gas data reporting.
9/2/2021	New gas data loaded with back data to NYSERDA DER website.

Table 3. Range Checks

Data Point	Units	Hourly Data Calculation Method	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output (WG_d)	kWh/int	Sum	0	125	
DG/CHP Generator Outpt Demand (WG_KW_d)	kW	Max	0	500	$WG\_KW\_d = WG\_d * \# \text{ Intervals}$
DG/CHP Generator Gas Use (FG_d)	Cfh/int	Sum	0	2,500	
Total Facility Purchased Energy (WT_d)	kWh/int	-	0	-	
Total Facility Purchased Demand (WT_KW_d)	kW	-	0	-	
Other Facility Gas Use (FT_d)	cf/int	-	-	-	
Useful Heat Recovery (QHR_d)	MBtu	-	0	-	
Unused Heat Recovery (QD_d)	MBtu	-	0	-	
Status/Runtime of DG/CHP Generator (SG_d)	hr	-	0	1	0-1, System On/System Off
Ambient Temperature (TAO)	°F	Avg	-20	130	WUG Airport Code: MSS

Notes:

1. This table contains values from *woodcrest.csv*