

Onondaga County – Metro Water Board – Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	SolarCity Daily sftp 15 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	180° 10° 1362.13 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Accumulator
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Calculated

Table 2 Event Timeline

Date	Event
May 13, 2016	Monitored data collection began
May 23, 2016	Monitored data posted on the NYSERDA DG Website

Table 3 Range Checks

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	350	
DG/CHP Generator Output Demand	Max	kW	0	1500	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code - SYR

Notes: Table contains values from *onondaga_metro_solar.csv*