

Gas service for the site Westmont was turned back on in April of 2022. However, the gas meter on site was removed. To back fill the gas data a gas factor was acquired by finding the trend line of the Electricity Generated vs. Fuel Consumption and using the slope of the line to correct the data.

The plots below show the past measured data and the gas data based on the gas factor. The multiplier gas factor that Frontier Energy applied was $Y = 9.752(X) + 218.28$.

