



RECORD
DRAWING
12-18-01

CHK
BY:
W.J.F.

DAKWOOD
HEALTH CARE CENTER
200 BASSETT RD.
WILLIAMSVILLE, NY

LEGEND

- MANUAL (BALL) VALVE
- DYNAMIC AUTOMATIC BALANCING VALVE
- DYNAMIC AUTOMATIC BALANCING VALVE (CIRCUIT SETTER)
- TRIPLE DUTY VALVE
- SWING CHECK VALVE
- AIR SEPARATOR
- TEMPERATURE SENSOR
- PRESSURE GAUGE
- FLOW METER
- FLOW SWITCH
- MODIFICATIONS TO EXISTING SYSTEM
- PRESSURE RELIEF VALVE
- THERMOMETER
- AIR VENT
- DRAIN
- INLINE PUMP
- BASE MOUNTED PUMP
- STRAINER OR SUCTION DIFFUSER
- 3-WAY CONTROL VALVE
- 2-WAY CONTROL VALVE

PUMP SCHEDULE				
NO.	GPM	FT HEAD	HP	MODEL
P-3	80	125	5	B&G SER. 80
P-4	80	125	5	1 1/2 X 1 1/2 X 7B

NOTES:

1. SYSTEM FLUID IS 40% ETHYLENE GLYCOL.
2. PUMP GPM AND FT. HEAD IS TOTAL WITH BOTH PUMPS RUNNING TOGETHER.

GERSTER TRANE
45 EARHART DR.
SUITE 103
WILLIAMSVILLE, NY
PHONE: 716-626-1260
FAX: 716-626-9412

JOB NO: 900864
DATE: 5-23-01
DRAWN BY: WFL
CHK BY: TAL
SCALE: NONE

NUM	DATE	BY
1	5-24-01	WFL
2	5-31-01	WFL
3	12-18-01	WFL

DRAWING TITLE:
COGENERATION
SYSTEM
HEAT RECOVERY
PIPING SCHEMATIC

DRAWING NUMBER:
M-3