Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method:	Obvius AcquiSuite A8812 1 – Minute Obvius Upload Manager to CDH Servers
Site Information	Cogeneration Units: Nameplate Capacity: Heat Recovery Medium: Heat Recovery Uses: Excess Heat:	Aegen TP-75LE Induction w/ Inverter 75 kW Hot Water Domestic hot water Rejected to atmosphere by dump radiator
DG/CHP Generator Electrical Output	Engineering Units: Energy Measurement (net/gross): Measurement Type:	kWh Net Power (calculated from gross and parasitic measurements) Accumulated kWh
DG/CHP Generator Electrical Output Demand	Engineering Units: Measurement Type:	kW Calculated : accumulated kWh/int * # intervals
DG/CHP Generator Fuel Input	Engineering Units: Measurement type:	CF Accumulated cubic feet
DG/CHP Useful Heat Recovery	Engineering Units: Heat Measurement Type:	MBtu/hr Calculated from 1 minute analog flow and temperature data
DG/CHP Unused Heat Recovery	Engineering Units: Heat Measurement Type:	MBtu/hr Calculated from 1 minute analog flow and temperature data
DG/CHP Status/Runtime	Engineering Units: Measurement Type:	Hours Calculated based on generator output

Facility Purchased Energy	Engineering Units: Measurement Type:	kWh Accumulated kWh
Facility Purchased Demand	Engineering Units: Measurement Type:	kW Calculated: accumulated kWh/int * # intervals
Other Facility Gas Use	Engineering Units: Measurement Type:	-

Table 2 Event Timeline

Date	Event
October 19, 2016	On site to install datalogger, terminate meter wiring, setup communications, and verify sensor readings. Data collection begins.
Dec 5, 2016	Website data begins December 3, 2016

Range Checks

Table 3. Range Checks

Data Point	Units	Hourly Data Calculation Method	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output (WG_d)	kWh/int	Sum	0	80	
DG/CHP Generator Output Demand (WG_KW_d)	kW	Max	0	80	$WG_KW_d = WG_d * # Intervals$
DG/CHP Generator Gas Use (FG_d)	cf/int	Sum	0	2500	
Total Facility Purchased Energy (WT_d)	kWh/int	Sum	0	400	
Total Facility Purchased Demand (WT_KW_d)	kW	Max	0	400	$WT_KW_d = WT_d * \# Intervals$
Other Facility Gas Use (FT_d)	cf/int	-	-	-	
Useful Heat Recovery (QHR_d)	MBtu/hr	Avg	0	1000	
Unused Heat Recovery (QD_d)	MBtu/hr	Avg	0	1000	
Status/Runtime of DG/CHP Generator (SG_d)	hr	-	-	-	
Ambient Temperature (TAO)	°F	Avg	-20	130	WUG Airport Code - NYC

Notes:

1. This table contains values from *petersfield.csv*

Relational Checks

Table 4. Relational Checks

Evaluated Point	Criteria	Result

Notes:

1. This table contains values from relational_checks.pro