

RIT – Database Notes

Table 1 Database Notes

Data Collection	<u>Data Logger:</u> <u>Data Collection Interval:</u> <u>Collection Method:</u>	Obvius Acquisuite Data logger samples all sensors approximately once per second and records one-minute totals (of pulse or digital sensors) or averages (of analog sensors) Obvius upload to CDH Energy Server and to the Obvius Building Manager Online (BMO) system
Site Information	<u>Cogeneration Units:</u> <u>Nameplate Capacity:</u> <u>Heat Recovery Medium:</u> <u>Heat Recovery Uses:</u> <u>Excess Heat:</u>	UTC Power 400 kW Fuel Cell 400 kW Hot water loop Space Heating/Domestic Hot Water Pre-heat Rejected through the hot water/glycol loop to heat exchanger with dump radiator
DG/CHP Generator Electrical Output	<u>Engineering Units:</u> <u>Energy Measurement (net/gross):</u> <u>Measurement Type:</u>	kWh Net Accumulated energy per interval
DG/CHP Generator Electrical Output Demand	<u>Engineering Units:</u> <u>Measurement Type:</u>	kW Read from Shark Meter
DG/CHP Generator Fuel Input	<u>Engineering Units:</u> <u>Measurement type:</u>	CF Calculated from total gas use accumulator
DG/CHP Useful Heat Recovery	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	MBtu Onicon F-1211 Flow meters and Veris 10k Type 2 thermistors measure flow and temperatures across useful loads

RIT – Database Notes

DG/CHP Unused Heat Recovery	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	MBtu Onicon F-1111 Flow meters and Veris 10k Type 2 thermistors measure flow and temperatures across useful loads
DG/CHP Status/Runtime	<u>Engineering Units:</u> <u>Measurement Type:</u>	Hr Runtime accumulator is used to calculate runtime per interval
Facility Purchased Energy	<u>Engineering Units:</u> <u>Measurement Type:</u>	Not Collected
Facility Purchased Demand	<u>Engineering Units:</u> <u>Measurement Type:</u>	Not Collected
Other Facility Gas Use	<u>Engineering Units:</u> <u>Measurement Type:</u>	Not Collected

Table 2 Event Timeline

Date	Event
April 22, 2013	All heat recovery sensors installed
January 28, 2014	Shark Meter installed

RIT – Database Notes

Range Checks

Table 3. Range Checks

Data Point	Units	Hourly Data Calculation Method	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output (WG_d)	kWh/int	Sum	0	10	
DG/CHP Generator Output Demand (WG_KW_d)	kW	Max	0	500	
DG/CHP Generator Gas Use (FG_d)	cf/int	Sum	0	100	
Total Facility Purchased Energy (WT_d)	kWh/int	-			Not Collected
Total Facility Purchased Demand (WT_KW_d)	kW	-			Not Collected
Other Facility Gas Use (FT_d)	cf/int	-			Not Collected
Useful Heat Recovery (QHR_d)	MBtu/int	Avg	0	3000	Calculated Value
Unused Heat Recovery (QD_d)	MBtu/int	Avg	0	3000	Calculated Value
Status/Runtime of DG/CHP Generator (SG_d)	hr	Sum	0	1	Calculated Value
Ambient Temperature (TAO)	°F	Avg	-30	120	WUG Airport Code - ROC

Notes:

1. This table contains values from *rit.csv*

RIT – Database Notes

Relational Checks

Table 4. Relational Checks

Evaluated Point	Criteria	Result

Notes:

1. This table contains values from *relational_checks.pro*