

**MONITORING PLAN
FOR THE
PURECELL 400 FUEL CELL
AT
ROCHESTER INSTITUTE OF TECHNOLOGY
IN
ROCHESTER, NY**

Draft

April 23, 2013

Submitted to:

Clear Edge Power
195 Governor's Hwy
South Windsor, CT 06074

Submitted by:

CDH Energy Corp.
PO Box 641
2695 Bingley Rd.
Cazenovia, NY 13035
(315) 655-1063

TABLE OF CONTENTS

| | |
|--------------------------------------|---|
| Introduction..... | 1 |
| System Description..... | 1 |
| Heat Recovery Monitoring System..... | 1 |
| Calculated Quantities..... | 3 |
| Project Web Site..... | 5 |

Appendix A – Monitoring System Details

Introduction

This plan describes our approach to monitoring the performance of the fuel cell systems installed at Rochester Institute of Technology (RIT) in Rochester, NY. The Clear Edge Power PureCell® Model 400 fuel cell provides clean and efficient electric power and thermal output to the facility. This fuel cell is expected to supply electricity in addition to standby power in the event of a power grid failure. The facility will also recover heat from the fuel cells to use for space and Domestic Hot Water (DHW) heating.

System Description

The PureCell® Model 400 unit is installed on the RIT campus. The fuel cell (FC) has separate electrical feeds for parallel operation with the utility or to provide backup power when isolated from the grid. The fuel cell is able to provide 400 kW of electrical power and up to 1.7 million Btu/h of heat. If fully utilized, the fuel cell can obtain a thermal efficiency near 90%.



Power Output: 400 kW
480V, 3ph

Heat Output: 1.55 MMBtu/h
(low temp)

0.59 MMBtu/h
(high temp)

Figure 1. PureCell 400 Unit

Most of the thermal output from the FC is used to provide space conditioning and water heating for the university. The low temperature loop supplies 130°F water to meet Domestic Hot Water (DHW) loads (see Figure 3). The high temperature loop supplies 180°F water to meet space heating and other building loads.

Heat Recovery Monitoring System

The heat recovery monitoring system (HRM) has been designed to capture the electrical and thermal performance of the system. Table 1 summarizes the measurements that will be captured at the site.

Figure 3 shows where the measurements will be made in the thermal loops. Flow and temperature sensors are installed for three thermal loops: low temperature, high temperature, and cooling water.

Data are extracted from the Power Plant Controller (PPC) via MODBUS TCP and from the Shark Power Meter via MODBUS 485/serial connections.. The Obvius AcquiSuite datalogger logs the required data.

Table 1. Summary of Measured and Collected Data at the Site

| Channel / Source | Data Pt | Description | Instrument / Meter | Signal / Register | Eng Units | Wire | Notes |
|------------------|-----------|---------------------------------------------|------------------------|-------------------|-----------|--------------|---------------------------|
| Main-1 | TLS | Low Temp Supply Temp (from FC) | 10k Thermistor, Type 2 | ohm | °F | 6 | |
| Main-2 | TLR | Low Temp Return Temp (to FC) | 10k Thermistor, Type 2 | ohm | °F | 5 | |
| Main-3 | THS | High Temp Supply Temp (from FC) | 10k Thermistor, Type 2 | ohm | °F | 4 | |
| Main-4 | THR | High Temp Return Temp (to FC) | 10k Thermistor, Type 2 | ohm | °F | 3 | |
| Main-5 | TCWS | Cooling Module Supply Temp (from FC) | 10k Thermistor, Type 2 | ohm | °F | 1 | |
| Main-6 | TCWR | Cooling Module Return Temp (to FC) | 10k Thermistor, Type 2 | ohm | °F | 2 | |
| EXP-1 | FL | Low Temp Water Flow | Onicon F-1211 | 4-20 mA | gpm | 4/7 | 2.5" Sch 40 Steel, 50 gpm |
| EXP-2 | FH | High Temp Water Flow | Onicon F-1211 | 4-20 mA | gpm | M1/M2 | 2.5" Sch 40 Steel, 50 gpm |
| EXP-3 | FCW | Cooling Module Flow | Onicon F-1111 | 4-20 mA | gpm | F/G | 2" Copper Type L, 60 gpm |
| Modbus Dev 2 | WREC_pos | Energy Output through Grid Independent Loop | Shark 100 | 1100 | kWh | | |
| Modbus Dev 2 | WREC_neg | Energy Input through Grid Independent Loop | Shark 100 | 1102 | kWh | | |
| Modbus Dev 2 | WREC | Power through Grid Independent Loop | Shark 100 | 900 | Watts | | |
| Modbus TCP | FG | Instantaneous Fuel Flow | PPC | 7173 | kg/h | Float | page 12 of FCFR |
| Modbus TCP | FGcum | Cumulative Fuel Consumption | PPC | 7191 | m³ | Float | page 12 of FCFR |
| Modbus TCP | WFC | Instantaneous Power Output | PPC | 10535 | kW | Float | page 12 of FCFR |
| Modbus TCP | WFCcum | Cumulative Power Produced | PPC | 7217 | MWh | Float | page 12 of FCFR |
| Modbus TCP | EFF_ELEC | Instantaneous electrical efficiency (LHV) | PPC | 7505 | % | Float | page 12 of FCFR |
| Modbus TCP | FC_STATE | Fuel Cell Mode/State Number | PPC | 5 | Number | Unsigned Int | page 12 of FCFR |
| Modbus TCP | RTIME | Cumulative "Load" Time | PPC | 7205 | hrs | Float | page 12 of FCFR |
| Modbus TCP | NALARM | Total number of alarms | PPC | 21 | Number | Unsigned Int | page 12 of FCFR |
| Modbus TCP | FC_ISTATE | Fuel Cell Inverter State Number | PPC | 13 | Number | Unsigned Int | page 12 of FCFR |
| Modbus TCP | SWV | Make-up water tank fill valve status | PPC | 763 | On/Off | Boolean/Int | page 12 of FCFR |
| Modbus TCP | SGI | Grid independent status | PPC | 60 | On/Off | Boolean/Int | page 12 of FCFR |
| Modbus TCP | SGC | Grid connect status | PPC | 59 | On/Off | Boolean/Int | page 12 of FCFR |

Note: EXP = Obvius expansion board, device 003
Main = Obvius main board, device 250




Figure 3. Schematic of Heat Transfer Loops in Fuel Cell System

The monitoring system is based around the Obvius AcquiSuite data logger. The layout of the HRM and the connections with other network components of the Fuel Cell system are shown in Figure 7. A Babel Buster gateway device reads MODBUS data from the PPC and makes that data available to the Obvius data logger.




Figure 7. Layout of HRM, RMS and PPC Network

Calculated Quantities

Heat Recovery Rates

The data to determine the delivered heat recovery energy and the delivered cooling will be collected by the datalogger at each scan interval and then averaged for each 15-minute recording interval. The calculations listed below will be completed before the data are displayed on the web site:

$$Q_{lo} = \frac{1}{n} \sum_{i=1}^n k_{lo} \cdot FL_i \cdot (TLS_i - TLR_i)$$

$$Q_{hi} = \frac{1}{n} \sum_{i=1}^n k_{hi} \cdot FH_i \cdot (THS_i - THR_i)$$

$$Q_{cw} = \frac{1}{n} \sum_{i=1}^n k_{cw} \cdot FCW_i \cdot (TCWS_i - TCWR_i)$$

where: Q_{xx} - Delivered heat recovery for loop xx (Btu/h)
 ($xx :: lo =$ low temp, $hi =$ high temp,
 $cw =$ cooling water)
 k_{xx} - density specific heat product constant for fluid in loop xx
 i - i^{th} scan (or read)
 n - number of scans in the averaging period

The loop fluid is expected to be water with propylene glycol (e.g., DowFrost). The factor k is equal to:

Low Temp Loop: $k_{lo} = 456.6 \text{ Btu/h} \cdot \text{gpm} \cdot ^\circ\text{F}$ for 40% glycol at 130°F
 High Temp Loop: $k_{hi} = 459.3 \text{ Btu/h} \cdot \text{gpm} \cdot ^\circ\text{F}$ for 40% glycol at 180°F
 Cooling Water Loop: $k_{cw} = 457.7 \text{ Btu/h} \cdot \text{gpm} \cdot ^\circ\text{F}$ for 40% glycol at 150°F

The Useful and Unused heat recoveries will be:

$$Q_{useful} = Q_{lo} + Q_{hi}$$

$$Q_{unused} = Q_{cw}$$

Power and Energy

Generally power meters can provide a host of data points, many of them redundant. Our approach, where possible, is to grab the register value associated with energy (kWh) and from that value determine the average power for each 15-minute interval. This average power value is defined as:

$$\text{kW}_{\text{avg}} = \frac{\text{kWh}}{\Delta t}$$

This average Power over a short time interval (15 minutes) is usually indistinguishable from the “demand” or instantaneous power data reported by most meters (most utilities use a sliding 15-minute interval). The fuel cell PPC and the Shark meter are both given as instantaneous kW. Cumulative reads are in kWh.

Efficiency Calculations

The electrical and total efficiency of the Fuel Cell, based on the lower heating value of the fuel, will be calculated using:

$$\eta_{\text{electrical}} = \frac{WFC}{LHV \times FG \times \frac{1}{3600}}$$

$$\eta_{\text{total}} = \frac{WFC + (QL + QH) \times \frac{1}{3412.8}}{LHV \times FG \times \frac{1}{3600}}$$

where: QL, QH - Useful heat recovery – low, high temperature loops (Btu/h)
 WFC - Power output (kW)
 FG - Generator gas input (kg/h)
 LHV - Lower heating value for natural gas (~48,667 kJ/kg)

Project Web Site

CDH will create a web site for RIT that provides access to all the historic data collected at the site. The website will provide custom, detailed plots and tables of the collected data from the site that will be updated once a day.

Appendix A - Fuel Cell HRM at RIT

Internet address: <166.143.94.237>

Table 1. Summary of Major HRM Components

| | |
|------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Obvius AcquiSuite A8812 | This datalogger includes thermistors and flow meters to measure thermal loads. It also reads MODBUS registers from the Babel Buster . All data are stored in the AcquiSuite memory and transferred to the CDH Energy servers from this device. |
| Control Solutions Babel Buster BB2-7010-01 | This gateway device reads data from the PPC (via MODBUS TCP) and makes it available as MODBUS data to the AcquiSuite . |

Table 2. Summary of Data Sensors

| | |
|------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Power Plant Controller PPC | This fuel cell controller provides data as MODBUS registers to the Babel Buster . |
| Onicon F-1111 Flow Meter | This high accuracy, insertion-style, impeller flow meter measures water flow through each of the heat loops and provides a 4-20mA signal to the AcquiSuite . |
| Onicon F-1211 Flow Meter | Like the Onicon F-1111 , this is a highly accurate, insertion-style, impeller flow meter. The F-1211 is designed to handle a shorter straight length of pipe. |
| Veris TIG series Thermistor | This 10k Ω Type 2 Thermistor reacts to temperatures in the heat loops. The resulting resistances are measured and stored by the AcquiSuite . |
| Shark 100 Power Meter | This power meter is revenue grade will measure the electrical output of the fuel cell. This meter will communicate with the Acquisuite via MODBUS RTU. |




Figure 1. Layout of HRM and RMS Network

The Babel Buster provides all the communications (i.e., reads) between the devices on the network. It reads data from the PPC device and makes the data available for the Obvius AcquiSuite datalogger to read. The AcquiSuite logs all the data.

Table 3. Network Devices and Addresses

Network Layout

| Label | Device | Protocol | IP Address |
|--------------|--------------------------------------------|----------------------|---------------|
| AcquiSuite | Obvius AcquiSuite | Modbus TCP | 192.168.0.220 |
| Babel Buster | CSI Babel Buster 2 Multi-network Interface | Modbus TCP BACnet | 192.168.0.221 |
| PPC | UTC Power Power Plant Controller (PPC) | Modbus TCP | 192.168.0.10 |
| Shark | Shark 100 - REC Power Transducer | Modbus RTU | |

Table 4. Listing of Data Points Collected from all Devices

| Babel Buster Variable | Source | CDH Name | CEP / Obvius Variable Name | Description | Native Units | Babel Buster MODBUS Address | Source Data Address | Source Data Type | Notes | Babel Buster Data Type | Eng Units |
|-----------------------|--------|-----------|----------------------------|--------------------------------------------------|----------------|-----------------------------|---------------------|------------------|-------|------------------------|----------------|
| AI-1 | PPC | FG | FUEL | Fuel flow rate | kg/h | 1 | 7173 | Float | | Float | kg/h |
| AI-2 | PPC | FGcum | CUMFUEL | Cumulative fuel consumed at standard temperature | m ³ | 3 | 7191 | Float | | Float | m ³ |
| AI-3 | PPC | WFC | KW | Electrical power output | kW | 5 | 10535 | Float | | Float | kW |
| AI-4 | PPC | WFCcum | MWH | Cumulative electrical power output | MWh | 7 | 7217 | Float | | Float | MWh |
| BI-1 | PPC | SWV | WTRVLV | Make-up water tank fill valve status | On/Off | 3001 | 763 | Boolean/Int | | Boolean | On/Off |
| AI-5 | PPC | EFF_ELEC | EFFELEC | Instantaneous electrical efficiency | % | 9 | 7505 | Float | | Float | % |
| AI-6 | PPC | FC_STATE | STATE | Fuel cell state Number | Number | 11 | 5 | Unsigned Int | | Float | Number |
| BI-2 | PPC | SGI | GISTATUS | Grid independent status | On/Off | 3002 | 60 | Boolean/Int | | Boolean | On/Off |
| BI-3 | PPC | SGC | CGSTATUS | Grid connect status | On/Off | 3003 | 59 | Boolean/Int | | Boolean | On/Off |
| AI-7 | PPC | RTIME | LOAD | Cumulative load time hr | hrs | 13 | 7205 | Float | | Float | hrs |
| AI-8 | PPC | NALARM | NUMALARMS | Total number of alarms | Number | 15 | 21 | Unsigned Int | | Float | Number |
| AI-12 | PPC | FC_ISTATE | ISTATE | Inverter State Number | Number | 23 | 13 | Unsigned Int | | Float | Number |
| AI-9 | SHARK | WREC_pos | WREC_pos | Energy Output through Grid Independent Loop | kWh | 17 | 1100 | Double | | Float | kWh |
| AI-10 | SHARK | WREC_neg | WREC_neg | Energy Input through Grid Independent Loop | kWh | 19 | 1102 | Double | | Float | kWh |
| AI-11 | SHARK | WREC | WREC | Power through Grid Independent Loop | Watts | 21 | 900 | Float | | Float | Watts |
| Main-1 | TLS | TEMPLGOUT | TEMPLGOUT | Temperature – low grade heat supply | °F | 39 | ohm | 10k, Type 2 | | Float | Ohms |
| Main-2 | TLR | TEMPLGIN | TEMPLGIN | Temperature – low grade heat return | °F | 41 | ohm | 10k, Type 2 | | Float | Ohms |
| Main-3 | THS | TEMPHGOUT | TEMPHGOUT | Temperature – high grade heat supply | °F | 43 | ohm | 10k, Type 2 | | Float | Ohms |
| Main-4 | THR | TEMPHGIN | TEMPHGIN | Temperature – high grade heat return | °F | 45 | ohm | 10k, Type 2 | | Float | Ohms |
| Main-5 | TCWS | TEMPCWOUT | TEMPCWOUT | Temperature – cooling module supply | °F | 47 | ohm | 10k, Type 2 | | Float | Ohms |
| Main-6 | TCWR | TEMPCWIN | TEMPCWIN | Temperature – cooling module return | °F | 49 | ohm | 10k, Type 2 | | Float | Ohms |
| EXP-1 | FL | FLOWLG | FLOWLG | Flow rate – low grade heat | gpm | 55 | 4-20 mA (0-100) | Onicon F-1211 | | Float | mA x 1000 |
| EXP-2 | FH | FLOWHG | FLOWHG | Flow rate – high grade heat | gpm | 57 | 4-20 mA (0-100) | Onicon F-1211 | | Float | mA x 1000 |
| EXP-3 | FCW | FLOWCW | FLOWCW | Flow rate – cooling module | gpm | 59 | 4-20 mA (0-150) | Onicon F-1111 | | Float | mA x 1000 |

= Data provided or received from PPC via MODBUS TCP

= Data from sensors on Obvius AcquiSuite

= Data received from the Shark 100 Power Meter

Babel Buster XML File

```
<?xml version="1.0" encoding="ISO-8859-1"?>
<!-- Babel Buster BB2-7010-01 v2.34.5 (db:2) configuration file -->
<configuration>

  <bacnet_objects>
    <obj id="1" name="FUEL" units="95"/>
    <obj id="2" name="CUMFUEL" units="95"/>
    <obj id="3" name="KW" units="95"/>
    <obj id="4" name="MWH" units="95"/>
    <obj id="5" name="EFFELEC" units="95"/>
    <obj id="6" name="STATE" units="95"/>
    <obj id="7" name="LOAD" units="95"/>
    <obj id="8" name="NUMALARMS" units="95"/>
    <obj id="12" name="ISTATE" units="95"/>
    <obj id="13" name="SERIAL" units="95"/>
    <obj id="3001" name="WTRVLV" units="95"/>
    <obj id="3002" name="GISTATUS" units="95"/>
    <obj id="3003" name="CGSTATUS" units="95"/>

    <obj id="20" name="AcquiSuite TLS" units="95"/>
    <obj id="21" name="AcquiSuite TLR" units="95"/>
    <obj id="22" name="AcquiSuite THS" units="95"/>
    <obj id="23" name="AcquiSuite THR" units="95"/>
    <obj id="26" name="AcquiSuite TCWS" units="95"/>
    <obj id="27" name="AcquiSuite TCWR" units="95"/>

    <obj id="28" name="AcquiSuite FL" units="95"/>
    <obj id="29" name="AcquiSuite FH" units="95"/>
    <obj id="31" name="AcquiSuite FCW" units="95"/>
  </bacnet_objects>

  <modbus_devices>
    <dev id="1" ipaddr="192.168.0.10" unit="1" rate="1.000000" name="UTC PPC" swapped="1"/>
    <dev id="2" ipaddr="192.168.0.220" unit="250" rate="1.000000" name="AcquiSuite Main Board"/>
    <dev id="3" ipaddr="192.168.0.220" unit="3" rate="1.000000" name="AcquiSuite Exp Board"/>
    <dev id="4" ipaddr="192.168.0.220" unit="2" rate="1.000000" name="Shark 100 Power Meter"/>
  </modbus_devices>

  <client_read>
    <rule localreg="1" remtype="hold_reg" remreg="7173" remfmt="float" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="FUEL"/>
    <rule localreg="2" remtype="hold_reg" remreg="7191" remfmt="float" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="CUMFUEL"/>
    <rule localreg="3" remtype="hold_reg" remreg="10535" remfmt="float" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="KW"/>
    <rule localreg="4" remtype="hold_reg" remreg="7217" remfmt="float" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="MWH"/>
    <rule localreg="5" remtype="hold_reg" remreg="7505" remfmt="float" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="EFFELEC"/>
    <rule localreg="6" remtype="hold_reg" remreg="5" remfmt="uint" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="STATE"/>
    <rule localreg="7" remtype="hold_reg" remreg="7205" remfmt="float" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="LOAD"/>
    <rule localreg="8" remtype="hold_reg" remreg="21" remfmt="uint" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="NUMALARMS"/>
    <rule localreg="12" remtype="hold_reg" remreg="13" remfmt="uint" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="ISTATE"/>
    <rule localreg="13" remtype="hold_reg" remreg="20" remfmt="uint" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="SERIAL"/>
    <rule localreg="3001" remtype="coil" remreg="763" remfmt="int" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="WTRVLV"/>
    <rule localreg="3002" remtype="coil" remreg="60" remfmt="int" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="GISTATUS"/>
    <rule localreg="3003" remtype="coil" remreg="59" remfmt="int" dev="1" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="CGSTATUS"/>

    <rule localreg="20" remtype="hold_reg" remreg="1" remfmt="double" dev="2" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="Acquisuite TLS"/>
    <rule localreg="21" remtype="hold_reg" remreg="3" remfmt="double" dev="2" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="Acquisuite TLR"/>
    <rule localreg="22" remtype="hold_reg" remreg="5" remfmt="double" dev="2" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="Acquisuite THS"/>
    <rule localreg="23" remtype="hold_reg" remreg="7" remfmt="double" dev="2" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="Acquisuite THR"/>
    <rule localreg="26" remtype="hold_reg" remreg="9" remfmt="double" dev="2" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="Acquisuite TCWS"/>
    <rule localreg="27" remtype="hold_reg" remreg="11" remfmt="double" dev="2" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="Acquisuite TCWR"/>
    <rule localreg="32" remtype="hold_reg" remreg="13" remfmt="double" dev="2" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="Acquisuite FGREC"/>

    <rule localreg="28" remtype="hold_reg" remreg="3" remfmt="double" dev="3" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="Acquisuite FL"/>
    <rule localreg="29" remtype="hold_reg" remreg="1" remfmt="double" dev="3" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="Acquisuite FH"/>
    <rule localreg="31" remtype="hold_reg" remreg="5" remfmt="double" dev="3" scale="0.000000" offset="0.000000" poll="1.00" bipunits="96" name="Acquisuite FCW"/>
  </client_read>

  <rtu_read>
    <rule localreg="9" remtype="hold_reg" remreg="1100" remfmt="double" unit="1" scale="0.000000" offset="0.000000" poll="0.00" name="MWHREC_POS"/>
    <rule localreg="10" remtype="hold_reg" remreg="1102" remfmt="double" unit="1" scale="0.000000" offset="0.000000" poll="0.00" name="MWHREC_NEG"/>
    <rule localreg="11" remtype="hold_reg" remreg="900" remfmt="float" unit="1" scale="0.000000" offset="0.000000" poll="0.00" name="KWREC"/>
  </rtu_read>

  <rtu_device>
    <dev baud="9600" slave="1" unit="3"/>
  </rtu_device>

</configuration>
```

Table 5. Sensor and Wiring Details for AcquiSuite

| Channel / Source | Data Pt | Description | Instrument / Meter | Signal / Register | Eng Units | Wire | Notes |
|------------------|-----------|---------------------------------------------|------------------------|-------------------|-----------|--------------|---------------------------|
| Main-1 | TLS | Low Temp Supply Temp (from FC) | 10k Thermistor, Type 2 | ohm | °F | 6 | |
| Main-2 | TLR | Low Temp Return Temp (to FC) | 10k Thermistor, Type 2 | ohm | °F | 5 | |
| Main-3 | THS | High Temp Supply Temp (from FC) | 10k Thermistor, Type 2 | ohm | °F | 4 | |
| Main-4 | THR | High Temp Return Temp (to FC) | 10k Thermistor, Type 2 | ohm | °F | 3 | |
| Main-5 | TCWS | Cooling Module Supply Temp (from FC) | 10k Thermistor, Type 2 | ohm | °F | 1 | |
| Main-6 | TCWR | Cooling Module Return Temp (to FC) | 10k Thermistor, Type 2 | ohm | °F | 2 | |
| EXP-1 | FL | Low Temp Water Flow | Onicon F-1211 | 4-20 mA | gpm | 4/7 | 2.5" Sch 40 Steel, 50 gpm |
| EXP-2 | FH | High Temp Water Flow | Onicon F-1211 | 4-20 mA | gpm | M1/M2 | 2.5" Sch 40 Steel, 50 gpm |
| EXP-3 | FCW | Cooling Module Flow | Onicon F-1111 | 4-20 mA | gpm | F/G | 2" Copper Type L, 60 gpm |
| Modbus Dev 2 | WREC_pos | Energy Output through Grid Independent Loop | Shark 100 | 1100 | kWh | | |
| Modbus Dev 2 | WREC_neg | Energy Input through Grid Independent Loop | Shark 100 | 1102 | kWh | | |
| Modbus Dev 2 | WREC | Power through Grid Independent Loop | Shark 100 | 900 | Watts | | |
| Modbus TCP | FG | Instantaneous Fuel Flow | PPC | 7173 | kg/h | Float | page 12 of FCFR |
| Modbus TCP | FGcum | Cumulative Fuel Consumption | PPC | 7191 | m³ | Float | page 12 of FCFR |
| Modbus TCP | WFC | Instantaneous Power Output | PPC | 10535 | kW | Float | page 12 of FCFR |
| Modbus TCP | WFCcum | Cumulative Power Produced | PPC | 7217 | MWh | Float | page 12 of FCFR |
| Modbus TCP | EFF_ELEC | Instantaneous electrical efficiency (LHV) | PPC | 7505 | % | Float | page 12 of FCFR |
| Modbus TCP | FC_STATE | Fuel Cell Mode/State Number | PPC | 5 | Number | Unsigned Int | page 12 of FCFR |
| Modbus TCP | RTIME | Cumulative "Load" Time | PPC | 7205 | hrs | Float | page 12 of FCFR |
| Modbus TCP | NALARM | Total number of alarms | PPC | 21 | Number | Unsigned Int | page 12 of FCFR |
| Modbus TCP | FC_ISTATE | Fuel Cell Inverter State Number | PPC | 13 | Number | Unsigned Int | page 12 of FCFR |
| Modbus TCP | SWV | Make-up water tank fill valve status | PPC | 763 | On/Off | Boolean/Int | page 12 of FCFR |
| Modbus TCP | SGI | Grid independent status | PPC | 60 | On/Off | Boolean/Int | page 12 of FCFR |
| Modbus TCP | SGC | Grid connect status | PPC | 59 | On/Off | Boolean/Int | page 12 of FCFR |

Table 6. Forwarded Addresses on Digi Modem

Forward TCP/UDP/FTP connections from external networks to the following internal devices:

| Enable | Protocol | External Port | Forward To Internal IP Address | Forward To Internal Port |
|-------------------------------------|----------|---------------|--------------------------------|--------------------------|
| <input checked="" type="checkbox"/> | UDP | 47808 | 192.168.0.51 | 47808 |
| <input checked="" type="checkbox"/> | TCP | 3389 | 192.168.0.199 | 3389 |
| | | | | |
| <input checked="" type="checkbox"/> | TCP | 8081 | 192.168.0.220 | 80 |
| <input checked="" type="checkbox"/> | TCP | 8082 | 192.168.0.221 | 80 |
| <input checked="" type="checkbox"/> | FTP | 8083 | 192.168.0.220 | 21 |
| <input checked="" type="checkbox"/> | TCP | 8084 | 192.168.0.220 | 23 |
| <input checked="" type="checkbox"/> | FTP | 0 | 0.0.0 | 0 |

Obvius AcquiSuite

The AcquiSuite data logger produces a separate file of 1-minute data for each device. The read map for the data logger is given below.

| <u>Chan Name</u> | <u>Device</u> | <u>Column</u> |
|------------------|---------------|---------------|
| FG, | mb-001, | 0 |
| FGCUM, | mb-001, | 1 |
| WFC, | mb-001, | 2 |
| WFCCUM, | mb-001, | 3 |
| SWV, | mb-001, | 4 |
| EFF_ELEC, | mb-001, | 5 |
| FC_STATE, | mb-001, | 6 |
| SGI, | mb-001, | 7 |
| SGC, | mb-001, | 8 |
| RTIME, | mb-001, | 9 |
| NALARM, | mb-001, | 10 |
| WREC_pos | mb-001, | 13 |
| WREC_neg | mb-001, | 14 |
| WREC | mb-001, | 15 |
| ISTATE, | mb-001, | 16 |
| FL, | mb-003, | 1 |
| FH, | mb-003, | 6 |
| FCW, | mb-003, | 11 |
| TLS, | mb-250, | 1 |
| TLR, | mb-250, | 6 |
| THS, | mb-250, | 11 |
| THR, | mb-250, | 16 |
| TCWS, | mb-250, | 21 |
| TCWR, | mb-250, | 26 |

Notes: mb-001 - MODBUS Reads
 mb-003 - AcquiSuite Expansion Board
 mb-250 - AcquiSuite Main Board

Sensor Calibrations:

| Thermistor # | Name | Wire | Input Channel | Mult | Offset |
|--------------|------|------|---------------|---------|--------|
| 4-167 | TLS | 6 | Main-1 | 0.99176 | 1.04 |
| 4-171 | TLR | 5 | Main-2 | 0.99340 | 0.89 |
| 4-173 | THS | 4 | Main-3 | 0.99192 | 0.95 |
| 4-166 | THR | 3 | Main-4 | 0.99155 | 0.95 |
| 2-37 | TCWS | 1 | Main-5 | 0.98871 | 0.90 |
| 2-36 | TCWR | 2 | Main-6 | 0.98836 | 0.97 |